



**CODES REFERENCE GUIDE**

<b>AREA</b>	<b>PRIMARY</b>	<b>SECONDARY</b>
Occupancy Classification	LSC	IBC
Building Construction Types including allowable height, building areas and the requirements for sprinkler protection related to minimum building construction types	IBC	LSC
Means of Egress	LSC	NONE
Standpipes	IBC	IFC
Interior Finish	LSC	NONE
HVAC Systems	IMC	NONE
Vertical Openings	LSC	NONE
Sprinkler Systems minimum construction standard	LSC	NONE
Fire Alarm Systems	LSC	NONE
Smoke Alarm and Detection Systems	State/LSC	NONE
Portable Fire Extinguishers	IFC	NONE
Cooking Equipment	LSC/NFPA 96	NONE
Fuel Fire Appliances	IFGC	NFPA 54
Liquid Petroleum Gas	NFPA 58	NFPA 54
Compressed Natural Gas	NFPA 52	None